

Development of Environmentally Sustainable Methods for Treatment of Domestic Wastewater and Handling of Sewage Sludge on Yap Island

by

Joseph D. Rouse



WERI

**WATER AND ENVIRONMENTAL RESEARCH INSTITUTE
OF THE WESTERN PACIFIC
UNIVERSITY OF GUAM**

**Technical Report No. 153
February 2015**

Development of Environmentally Sustainable Methods for Treatment of Domestic Wastewater and Handling of Sewage Sludge on Yap Island

By

Joseph D. Rouse

University of Guam
Water and Environmental Research Institute of the Western Pacific
UOG Station, Mangilao, Guam 96923

Technical Report No. 153

February 2015

The work reported herein was funded by the U.S. Geological Survey (USGS; Award No. G11AP20074), administrated through the Water and Environmental Research Institute of the Western Pacific (WERI) at the University of Guam. The content of this report does not necessarily reflect the views and policies of the USGS, nor does the mention of trade names or commerical products constitute their endorsement by the United States Government.

ACKNOWLEDGMENTS

The author would like to thank the people of the Yap State Public Service Corporation and the Yap EPA for their professional assistance provided unreservedly during the fieldwork stage of this project. In addition, special thanks are extended to Mr. Mathew Thigthen of the Yap EPA for assistance in conducting field work and to Mr. William M.C. Whitman of the University of Guam for assistance in obtaining GPS (global positioning system) data.

ABSTRACT

A survey was conducted of the wastewater treatment systems and related sludge handling practices on the island of Yap, in the Federated States of Micronesia, to assist in identifying areas where further work would be merited to improve on effectiveness and sustainability. A detailed inventory was made of communal septic tanks as found at health centers and schools. The precise location of each unit was determined and its condition was evaluated. Though most of these septic tanks appeared to be functional, there were concerns due to some units being positioned within the tidal zone, covered over with vegetation, or out of reach of the pump truck. Furthermore, the centralized wastewater treatment plant on Yap provides only primary treatment consisting of a limited removal of suspended solids. Thus nearly raw sewage is being discharged to the bay. Excess sludge is drawn from the treatment plant on a quarterly basis, which following drying is supposed to be transported to the landfill; however, local farmers regularly make use of it as fertilizer for crop application without adequate treatment. As an immediate target for further study and pilot testing, exploring the use of an attached-growth process as an inexpensive retrofit to enhance the effectiveness of the treatment plant is proposed. In addition, the benefits of implementing a composting program for recycle of waste sludge in a safe manner and developing a framework for management of septic tanks are discussed.

Keywords: wastewater; sewage sludge; treatment; sustainable infrastructure; tropical islands; Yap; Micronesia.

TABLE OF CONTENTS

ACKNOWLEDGMENTS	i
ABSTRACT	ii
TABLE OF CONTENTS	iii
LIST OF TABLES	iv
LIST OF FIGURES	iv
List of figures in Appendix	v
INTRODUCTION	1
METHODOLOGIES	3
PRINCIPAL FINDINGS AND DISCUSSION	3
Septic tanks	3
Landfill leachate	6
Wastewater treatment	8
Sludge handling	10
CONCLUSIONS	13
REFERENCES	13
APPENDIX	15

LIST OF TABLES

Table 1. Septic Tanks at Community Health Centers.	5
Table 2. Septic Tanks at Early Childhood Education Centers.	5
Table 3. Septic Tanks at Elementary Schools.	5
Table 4. Septic Tanks at other communal facilities.	5

LIST OF FIGURES

Figure 1. Map showing the island of Yap (upper-left corner) among the islands of Yap State of the Federated States of Micronesia. Image source: Aotearoa – Wikimedia Commons [4].	1
Figure 2. Map showing the island of Yap proper, of Yap State, consisting of four interconnected islands. Image source: Aotearoa – Wikimedia Commons [4]. ...	2
Figure 3. Large communal septic tank used in remotely located Daabach Village on Yap. Image source: author.	4
Figure 4. Newly constructed Fukuoka-type landfill on Yap prior to first use. Image source: author.	7
Figure 5. Leachate collection pond at the new landfill. White box on far side of pond is the sand filtration unit. Image source: author.	7
Figure 6. Detailed view of the sand filtration unit process at the new landfill. Image source: author.	8
Figure 7. Imhoff tank sewage treatment plant in Colonia, Yap. Image source: author.	9
Figure 8. One flow line in the Imhoff tank sewage treatment plant. Image source: author.	9

Figure 9. Imhoff tank emptied for inspection showing compartment where biocarrier matrix could be inserted. Image source: author.	10
Figure 10. Sewage sludge from Imhoff tank being discharged to drying bed. Image source: author.	11
Figure 11. Fresh wet sewage sludge in drying bed at beginning of drying period. Image source: author.	11
Figure 12. Air dried sludge with an estimated 50% solids content. Image source: author.	12
<hr/>	
Figures in Appendix (image source for all photos: author):	15
Figures 13–16: Facilities at Community Health Centers	16
Figures 17–24: Facilities at Early Childhood Education Centers	17–18
Figures 25–38: Facilities at Elementary Schools	18–20
Figures 39–42: Facilities at other locations	21
<hr/>	

INTRODUCTION

Inadequate treatment of domestic wastewater (or sewage) in the islands of the Western Pacific has been responsible for serious human and environmental health problems due to contamination of water supplies and damage to natural resources [1]. The reason for this has often been attributed to the lack of functional technologies, which are difficult to obtain and maintain due to the vast geographical distances among the island communities and the high costs for providing services.

Yap State (**Figure 1**), the western-most state of the Federated States of Micronesia (FSM), covers approximately 500,000 square miles (1,300,000 square kilometers) of ocean yet has only 45.8 square miles (119 square kilometers) of land surface, consisting of numerous small islands. Only about 20 of these are inhabited. The main island of Yap (**Figure 2**), traditionally called “Wa’ab,” is actually four closely interconnected continental islands with a population of approximately 7700 people, or 65% of the state population (estimated to be 11,863 persons in 2015 [2]) [3]. The only centralized wastewater treatment plant (WWTP) in the state is in the town of Colonia on the island of Yap. The treatment currently being provided, though, is clearly insufficient with nearly raw wastewater being discharged to the ocean near the population center. In addition, the numbers and locations of pit latrines and septic tanks on the island are not adequately inventoried and the degree of treatment and extent of upkeep being provided are largely unknown. Furthermore, excess sludge produced at the WWTP is used for agricultural purposes without prior treatment to meet appropriate standards for human safety. Thus, improved management of this potentially useful resource is urgently needed.

Figure 1. Map showing the island of Yap (upper-left corner) among the islands of Yap State of the Federated States of Micronesia. Image source: Aotearoa – Wikimedia Commons [4].



The objective of this project is to contribute to the development of an inventory of up-to-date information on the existing wastewater-related infrastructure on the island of Yap. Such an inventory would be of use in identifying existing problems and prioritizing areas where corrective action would be best directed in order to improve the overall functionality and sustainability of wastewater treatment and related practices on the island. This objective was met by conducting field surveys to document and characterize the existing wastewater treatment systems and related sludge handling practices on Yap. As practicable, these items are to include:

- (a) Identification of locations of individual treatment units (i.e., pit latrines and septic tanks), and evaluation of treatment efficiency.
- (b) Description of the centralized wastewater treatment plant, including design capacity and degree of treatment being achieved.
- (c) Description of excess sludge handling practices, including the quantity generated and degree of treatment being achieved.
- (d) Documentation of disposal practices for treated wastewater and sludge and evaluation of environmental and public health impacts.

Figure 2. Map showing the island of Yap proper, of Yap State, consisting of four interconnected islands. Image source: Aotearoa – Wikimedia Commons [4].



METHODOLOGIES

The methods employed over the course of this project incorporated civil and environmental engineering fieldwork. All work was carried out by the principal investigator with assistance of a student from the University of Guam. Prior to commencing fieldwork, points of contact in the Yap Environmental Protection Agency (Yap EPA) and utilities offices were established to clarify the intent of the investigation to the local authorities.

Fieldwork commenced by conducting meetings with pertinent local officials on utility boards and other government agencies to obtain guidance concerning locations and details of septic tanks and other wastewater treatment facilities. Subsequently, as practicable, the locations of these facilities were confirmed and documented by use of global positioning system (GPS) technology (Colorado 300, Garmin). Furthermore, the sole wastewater treatment plant and related disposal practices were inspected and documented.

PRINCIPAL FINDINGS AND DISCUSSION

Septic tanks

Septic tanks are reportedly being used as a first line of treatment for domestic wastewater at 31% of the 2311 households in Yap State [5], where a household on average consists of six persons. Almost all of these septic tanks – as concrete box structures – are located on the main island of Yap.

It was not practicable, nor considered advisable, to attempt to locate and inspect all the household septic tanks, which amounts to an estimated 700 units – all located on private property. The Yap EPA does not have a full accounting of the numbers and locations of septic tanks because to date there have been no enforceable regulations concerning their construction and placement. Registration of septic tanks only occurs when a loan or grant is involved, as with the construction or purchase of a house. Accordingly, over a recent four-year period, only 18 units have been formally noted in the agency's Septic Tank System Log. However, the Loan & Grant Division of the Yap Community Action Program does have design drawings for use in new construction of single compartment septic tanks. The design consists of a 4- X 5-foot (6-foot depth) reinforced concrete tank with an outlet to two parallel 20-foot leaching lines (8-foot separation). It is doubtful, though, that many of the existing residential units employ a leaching field, versus a leaching pit.

The Yap State Public Service Corporation responds to about three service calls per month to pump out septic tanks, which they provide for a fee of \$90 per tank. About once every year they encounter difficulties such as a septic tank being in an inaccessible location or not having an access port (manhole) built into the concrete structure. Overall, there are no outstanding problems with the use of septic tanks on the island that would demand immediate widespread corrective action. However, the impact of septic tank discharges on the quality of

groundwater, and possibly even coastal ocean water, could be difficult to discern apart from a well-directed sampling program.

With the assistance of the Yap EPA, it was considered reasonable to conduct a thorough inventory of communal septic tanks (**Figure 3**), such as those found at Community Health Centers (**Table 1**), Early Childhood Education Centers (**Table 2**), Elementary Schools (**Table 3**), and other miscellaneous facilities (**Table 4**). The general condition and functionality of each unit was documented and their precise locations determined by GPS. The GPS data, however, are not repeated in this report, but are made available separately for use by appropriate authorities.

As noted in the **Tables 1 - 4**, many of the communal septic tanks appeared to be fully functional and a duty manager with knowledge of the system was often present who could attest to periodic servicing. There were some concerns, though, such as the septic tank at Rumuu Early Childhood Education Center (**Table 2**), which is positioned in the tidal zone and encroached by seawater. In addition, there were a couple of tanks covered with vegetation (**Tables 2 & 3**), and one case where the location of the tank could not be visually confirmed (Gilman Elementary School, **Table 3**). In those cases it is doubtful whether the tanks are being properly maintained. Furthermore, at Maap/Tamilaeng Elementary School (**Table 3**) the septic tank was located down a steep slope in a forest growth and was out of reach of the pump truck. This septic tank was overloaded and extremely foul and no doubt will have to be abandoned in favor of a more suitable location in due time.

Figure 3. Large communal septic tank used in remotely located Daabach Village on Yap. Image source: author.



Table 1. Septic Tanks (STs) at Community Health Centers.

	Village/area	Comments
1	Maap/Rumuung	ST appears functional
2	Gagil	ST appears functional
3	Tomil	ST appears functional
4	Malaav	ST appears functional
5	Gilman	ST appears functional

Table 2. Septic Tanks (STs) at Early Childhood Education Centers.

	Village/area	Comments
1	Maap	ST appears functional
2	Rumuu	ST in ocean tidal zone
3	Gagil	ST appears functional
4	Tomil	ST appears functional
5	Dalipeebinaew	ST covered by vegetation
6	Kanifay	ST appears functional
7	Gilman	ST appears functional

Table 3. Septic Tanks (STs) at Elementary Schools.

	Village/area	Comments
1	Maap/Tamilaeng	Out of reach of pump truck
2	North Fanif	ST appears functional
3	SDA Campus	Seven functional STs
4	Rumuu	ST under outhouse
5	Bael	ST appears functional
6	Gagil	Holding tank only, no drainage
7	Tomil (B)	ST appears functional
8	Tomil (A)	ST appears functional
9	Dalipeedinaew	“Never been serviced”
10	Kanifay	ST covered by vegetation
11	Gilman	ST exact location not confirmable

Table 4. Septic Tanks (STs) at other communal locations.

	Village/area	Comments
1	Ablul Village	Two STs for village outhouses
2	Maritime Academy	STs not confirmed (out of scope)
3	Daabach Village	Large septic tank for village
4	Catholic High School	Large retrofitted ST

At the time of this report, an environmental lawyer was on a two-year assignment with the Yap EPA to develop environmental regulations that will, in part, cover the construction, placement, and operation of septic tanks and leaching fields. These regulations should start having positive environmental impacts in the not too distant future. Though not binding in the FSM, the Guam EPA has requirements for placing septic tanks and leaching fields that vary according to the geological features in different parts of the island. Yap likewise needs to determine the proper management of septic tanks with respect to the local environmental conditions. In the Philippines a National Sewerage and Septage Management Program was recently established to improve sanitation through a combined approach to fecal sludge management and septic tank cleaning [6]. The program employs a holistic approach offering advice on such issues as tariffs and fees, cleaning frequency of tanks, and methods to gain public participation. Early results have shown that there is no single right way to implement such a program and adaptation to local circumstances is critical. Nonetheless, lessons are being learned and best management practices are being developed, which may also be applicable on Yap and in other tropical regions.

Landfill leachate

Following in suit with the Fukuoka-type landfill installed in Kosrae, FSM, a few years ago, Yap State has also elected to construct the same type of landfill (nearly completed at the time of this study; **Figure 4**). While a landfill leachate collection and treatment system would more appropriately be classified as an industrial operation, due to this landfill being predominately for domestic solid waste, it will be briefly discussed in this report concerned with domestic wastewater. The uniqueness of the Fukuoka-type landfill is that ventilation is employed to promote aerated conditions throughout the landfill with the intent of preventing methane production. Considering that methane gas production at landfills is generally not rich enough to be put to use as an energy source, it is deemed more suitable to avoid anaerobic conditions and thus reduce the potential of methane escaping to the atmosphere where its reported effects would be much greater than that of carbon dioxide [7], as produced under aerobic conditions.

The leachate pond shown in **Figure 5** was holding only rainwater at the time of this report (prior to commencement of trash collection). Overflow from this pond passes through a sand filter (**Figure 6**) prior to being discharged to a forest gully. Effluent discharged from this new facility on Yap will be analyzed for chemical oxidation demand (COD) and pH. (Standards employed in Kosrae call for COD levels to be maintained below 100 mg/L and pH below 10, which have not been exceeded to date.) In the future a more aggressive form of leachate treatment may have to be considered if acceptable discharge levels for nutrients, heavy metals, or organic compounds are not maintained.

Figure 4. Newly constructed Fukuoka-type landfill on Yap prior to first use. Image source: author.



Figure 5. Leachate collection pond at the new landfill. White box on far side of pond is the sand filtration unit. Image source: author.



Figure 6. Detailed view of the sand filtration unit process at the new landfill. Image source: author.



Wastewater treatment

The municipal WWTP in Colonia (**Figure 7**), serving the main residential area and business center on Yap, was commissioned around 1974. The plant consists of an Imhoff tank system with two lines designed to operate in parallel (**Figure 8**); however, only one line is used at a time due to the relatively low intermittent flow entering the plant from only about 300 household connections. The unmetered inflow is thought to be somewhat less than the design flow of 170,000 gallons per day (640 cubic meters per day). Imhoff tanks are very user friendly and have low operational costs due to the absence of mechanical aeration and internal recycle. However, they provide only a primary level of treatment consisting of a limited removal of suspended solids. The solids that settle in a compartment below the flow channel are periodically expelled under the natural hydraulic head in the system, thus eliminating the need for mechanical pumping. No chemical or biological treatment is employed in the plant, hence the effluent, which is being discharged to the ocean, is not much different from raw sewage. Furthermore, the 1000-foot (300-meter) outfall is known to be broken open at approximately 500 feet (150 meters) from the shore. As a consequence, it is discharging sewage at a depth of 10 to 20 feet (3 to 6 meters) near the industrial district of Colonia about a half mile (one kilometer) from the main business district. Testing by the Yap EPA for Enterococci in the coastal zone has, surprisingly, yet to yield a count of greater than 30 per 100 millimeters, which would require the posting of warning signs.

Figure 7. Imhoff tank sewage treatment plant in Colonia, Yap. Image source: author.



Figure 8. One flow line in the Imhoff tank sewage treatment plant. Image source: author.



To upgrade the process to a conventional secondary level of treatment, a completely new plant would have to be constructed with a much larger footprint. Such a facility would require substantial capital and O&M costs. Another method worthy of consideration that could harness biological treatment power with a relatively simple addition to the existing facility would be to use an attached-growth (or biofilm) process [8, 9]. Using this method,

effective biomass could be retained in the unit process by use of a biocarrier support matrix. Potentially, as a relatively simple retrofit, biocarrier material could be attached to a frame and positioned in the existing tank so as to intercept the flow path of the wastewater. **Figure 9** shows the interior of one of the Imhoff tanks drained for inspection, where such a frame could be inserted. Evaluation of such an attached-growth process would be a avenue for future research and development.

Figure 9. Imhoff tank emptied for inspection showing compartment where biocarrier matrix could be inserted. Image source: author.



Sludge handling

Excess sludge is drawn from the bottom of the Imhoff tanks on approximately a quarterly basis (**Figures 10 & 11**). It is intended that following drying (**Figure 12**), the sludge would be transported to the solid waste landfill; however, before this can be done local farmers take it to be use as fertilizer for food crops. Currently, there is no regulatory guidance in Yap State concerning treatment requirements for sewage sludge prior to use. Though not binding in the FSM, the United States EPA offers widely accepted definitions for different classes of biosolids that could serve as a guideline [10]. Exceptional quality (Class A) biosolids, which have no crop harvesting restrictions, consist of treated residuals that contain no detectible levels of pathogens and low levels of heavy metals. Technologies that can meet Class A standards must process the biosolids for a sufficient length of time at a temperature high enough to yield a product in keeping with the required pathogen cut. Composting is one such

option that can be considered as an environmentally friendly method to recycle the nutrients and organic matter found in municipal wastewater solids. Depending on the level of treatment achieved, the cured compost could be used for production of food crops (if Class A), or for environmental reparation of badlands, which are abundant on Yap.

Figure 10. Sewage sludge from Imhoff tank being discharged to drying bed. Image source: author.



Figure 11. Fresh wet sewage sludge in drying bed at beginning of drying period. Image source: author.



Rigorous bacteriological testing should be used to evaluate the compost product prior to use. Where this is not possible, if standardized procedures are followed with respect to time and temperature of treatment (i.e., 30 days active composting with internal temperatures 55°C or higher for 15 days [11]), the quality of the final product can be assumed to meet Class A standards with a reasonable degree of certainty. However, if any questions concerning safety should emerge due to a lack of testing, applications avoiding contact with food crops, in keeping with more lenient standards, could readily be employed.

Figure 12. Air dried sludge with an estimated 50% solids content. Image source: author.



As the subject of a subsequent study, a pilot test could be conducted to evaluate the feasibility of developing a suitable composting practice at the WWTP. A rough estimate of the quantity of air dried excess sludge (ca. 50% solids) per sludge drawing event (about four times per year) comes to only 100 cubic feet, which should be a workable volume, not requiring the aid of special equipment. Notwithstanding, if a greatly expanded septic-tank sludge collection program were to be implemented (as discussed above), then further study would be necessary to scale the facility and equipment accordingly. The potential benefits of composting would include:

- (a) reducing solid waste input to the new landfill,
- (b) protecting the public from health hazards,
- (c) repairing badlands, and
- (d) generating revenue.

CONCLUSIONS

It is evident from this study that considerable progress has been made on Yap to bring the status of domestic wastewater treatment and sludge handling practices to a reasonable level of development. However, conclusions drawn here also suggest that further work is merited to achieve a higher degree of treatment in a more sustainable manner. More specifically, developing a framework for the management of septic tanks and implementing a composting program for recycle of waste sludge would do much to enhance public safety and environmental sustainability. In addition, exploring the use of an attached-growth process as an inexpensive means of improving the efficiency of the WWTP is proposed.

REFERENCES

1. Pacific Islands Applied Geoscience Commission. Pacific Wastewater Policy Statement. Available online:
<http://pacificwater.org/userfiles/file/water%20publication/WastewaterPolicy.pdf>
(accessed on 19 February 2015).
2. Office of Statistics, Budget and Economic Management, Overseas Development Assistance, and Compact Management (SBOC), Palikir, Pohnpei State, FSM. Available online:
<http://www.s boc.fm/index.php?id1=Vm0xMFIWbFdWWGhUYmxKVlIXczFVbFpyVWtKUFVUMDk> (accessed on 19 February 2015).
3. Maskarinec, G.G.; Yalmadau, K.; Maluchmai, M.R.; MO, P.T.; Yinnifel, C.; Hancock, W.T. Palliative care and traditional practices of death and dying in Wa'ab (Yap proper) and in the outer islands of Yap. *Hawai'i Medical Journal* **2011**, 70 (11, Supplement 2), 27-30. Available online: <http://www.ncbi.nlm.nih.gov/pmc/issues/204252/> (accessed on 19 February 2015).
4. Wikimedia Commons. Available online:
http://commons.wikimedia.org/wiki/Category:Maps_of_Yap (accessed on 19 February 2015).
5. Rouse, J.D. Sustainability of Wastewater Treatment and Excess Sludge Handling Practices in the Federated States of Micronesia. *Sustainability* **2013**, 5, 4183-4194. Available online: <http://www.mdpi.com/2071-1050/5/10> (accessed on 19 February 2015).
6. Robbins, D., Strande, L., Doczi, J. Sludge Management in Developing Countries. *Water* **21**, International Water Association. December 2012, pp. 22-25.

7. Schmidt, G.A. Methane: A Scientific Journey from Obscurity to Climate Super-Stardom. *Research Features*. National Aeronautics and Space Administration, Goddard Institute for Space Studies. September 2004. Available online: http://www.giss.nasa.gov/research/features/200409_methane/ (accessed on 19 February 2015).
8. Rouse, J.D., Yazaki, D., Cheng, Y., Koyama, T., Furukawa, K. Swim-bed Technology as an Innovative Attached-growth Process for High-rate Wastewater Treatment. *Japan. J. Water Treat. Biol.* 2004, 40 (3), pp. 115-124. Available online: https://www.jstage.jst.go.jp/browse/jswtb/40/3/_contents (accessed on 19 February 2015).
9. Rouse, J.D., Yoshida, N., Hatanaka, H., Imajo, U., Furukawa, K. Continuous Treatment Studies of Anaerobic Oxidation of Ammonium Using a Nonwoven Biomass Carrier. *Japan. J. Water Treat. Biol.* 2003, 39 (1), pp. 33-41. Available online: https://www.jstage.jst.go.jp/browse/jswtb/39/1/_contents (accessed on 19 February 2015).
10. U.S. Environmental Protection Agency. A Plain English Guide to the EPA Part 503 Biosolids Rule. Available online: http://water.epa.gov/scitech/wastetech/biosolids/503pe_index.cfm (accessed on 19 February 2015).
11. Benedict, A.H., Epstein, E., Alpert, J. *Composting Municipal Sludge. Pollution Technology Review* No. 152. Noyes Data Corp., Park Ridge, NJ, 1988. 177 pp.

APPENDIX

Supplemental Photographs

Septic tanks (STs) and related facilities in villages/municipalities of Yap



Community Health Centers
(Figures 13–16)

Early Childhood Education Centers
(Figures 17–24)

Elementary Schools
(Figures 25–38)

Other Locations
(Figures 39–42)

Septic tanks (STs) / facilities in Yap

Community	Health Centers
<p>Figure 13. ST (behind dog) at Community Health Center in Maap/Rumuung.</p> 	<p>Figure 14. Outhouse with ST at Community Health Center in Gagil.</p> 
<p>Figure 15. ST at Community Health Center in Tomil.</p> 	<p>Figure 16. ST in front of outhouse at Community Health Center in Malaav.</p> 

Septic tanks (STs) / facilities in Yap

Early Childhood

Education Centers

Figure 17. ST at Early Childhood Education Center in Maap.



Figure 18. ST at Early Childhood Education Center in Rumuu.



Figure 19. Outhouse at Early Childhood Education Center in Gagil.



Figure 20. ST beside outhouse (Fig. 19) at Early Childhood Education Ctr. in Gagil.



Figure 21. Outhouse and ST at Early Childhood Education Center in Tomil.



Figure 22. ST at Early Childhood Education Center in Dalipeebinaew.



Septic tanks (STs) / facilities in Yap

Figure 23. ST at Early Childhood Education Center in Kanifay.



Figure 24. ST at Early Childhood Education Center in Gilman.



Elementary Schools

Figure 25. ST at Elementary School in Maap/ Tamilaeng.



Figure 26. Outhouse at Elementary School in North Fanif.



Septic tanks (STs) / facilities in Yap

Figure 27. One of seven STs at SDA Elementary School in Tomil.



Figure 28. ST under outhouse at Elementary School in Rumuu.



Figure 29. ST at Elementary School in Bael (see detail in Fig. 30).



Figure 30. ST beside outhouse at Elementary School in Bael.



Figure 31. Outhouse at Elementary School in Gagil.



Figure 32. ST beside outhouse (Fig. 31) at Elementary School in Gagil.



Septic tanks (STs) / facilities in Yap

Figure 33. ST at Bldg-1 of Elementary School in Tomil.



Figure 34. ST at Bldg-2 of Elementary School in Tomil.



Figure 35. ST beside outhouse at Elementary School in Dalipeedinaew.



Figure 36. Outhouse at Elementary School in Kanifay.





Figure 37. ST behind Outhouse (Fig. 36) at Elementary School in Kanifay-B.



Figure 38. Outhouse at Elementary School in Gilman. ST location undetermined.



Septic tanks (STs) / facilities in Yap

Other	Locations
Figure 39. Outhouse/shower (one of two) for Ablul Village in very remote location.	Figure 40. Possible location of ST for Ablul Village outhouse (Fig. 39).
	
Figure 41. Large ST for Daabach Village in very remote location.	Figure 42. Large ST at Catholic High School campus in Rull Municipality.
