

PUMP TEST RESULTS

NO. NAS WELL NO. 1 DATE: 02-11-89 to 02-12-89
 STATIC WATER LEVEL: 276.67 MEASURING DEVICE: Electric Sounder
 MEASURING POINT: Ground Surface ELEVATION OF M.P. 282.33 +
 TESTER: hmp CONTRACTOR _____ GOVERNMENT _____

TIME	TIME SINCE PUMPING BEGAN(T) (MINUTES)	DISCHARGE (GPM)	WATER LEVEL (FEET)	DRAWDOWN (FEET)	COMMENTS
30	0	0	276.67	0	
31	1	254	289.40	12.73	
32	2	254	289.33	12.66	
33	3	254	289.33	12.66	
34	4	254	289.33	12.66	
35	5	254	289.50	12.83	
40	10	254	293.58	16.91	
45	15	254	293.50	16.83	
50	20	254	291.50	14.83	
55	25	254	292.08	15.41	
00	30	254	291.08	14.41	Pump Off
35	1	254	288.29	11.62	Restart Testing
36	2	254	291.67	15.00	Adjust Discharge
37	3	254	292.50	15.83	
38	4	254	291.58	14.91	
39	5	220	290.75	14.08	
40	6	220	290.58	13.91	
41	7	220	290.50	13.83	
42	8	220	290.67	14.00	
43	9	220	290.42	13.75	
44	10	220	290.50	13.83	
45	11	220	290.67	14.00	
50	16	220	290.67	14.00	
55	21	220	290.67	14.00	
00	26	220	290.75	14.08	
30	56	220	290.58	13.91	
00	86	220	290.58	13.91	

PUMP TEST RESULTS

NO. NAS WELL NO. 1

DATE: 02-11-89 to 02-12-89

STATIC WATER LEVEL: 276.67

MEASURING DEVICE: Electric Sounder

MEASURING POINT: Ground Level

ELEVATION OF M.P.

WITNESS:

CONTRACTOR

GOVERNMENT

TIME	TIME SINCE PUMPING BEGAN(T) (MINUTES)	DISCHARGE (GPM)	WATER LEVEL (FEET)	DRAWDOWN (FEET)	COMMENTS
4:30	116	220	290.17	13.50	
5:00	146	220	290.08	13.41	
6:00	206	220	290.08	13.41	
7:00	266	220	290.0	13.33	
8:00	326	220	290.0	13.33	
9:00	386	200	289.75	13.08	
10:00	446	200	289.71	13.04	7 HPA
11:00	506	200	289.71	13.04	
12:00	566	200	289.75	13.08	
1:00	626	200	289.42	12.75	
2:00	686	200	289.08	12.41	
3:00	746	200	289.08	12.41	
4:00	806	200	289.08	12.41	
5:00	866	200	288.75	12.08	
6:00	926	200	288.50	11.83	
7:00	986	200	288.50	11.83	
8:00	1046	200	288.50	11.83	
9:00	1106	200	288.50	11.83	
10:00	1166	200	288.38	11.71	
11:00	1226	200	288.38	11.71	
12:00	1286	200	288.38	11.71	
1:00	1346	200	288.25	11.58	
2:00	1406	200	288.25	11.58	
2:35	1440	200	288.25	11.58	